

DISTRICT LEVEL LABORATORY, CHAPRA (SARAN)

PUBLIC HEALTH DIVISION, CHAPRA

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 12.08.2025 BY MR. NIKHIL KUMAR & RECEIVED IN THE LABORATORY ON 12.08.2025

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1.	SARAN	REVELGAN	REVELGANL	EDUTECH MODEL SCHOOL, REVELGANJ, SARAN	0.86	719	481	182	190	44	16	26	15	0.07	0.00	0.23	321	BDL	Neg.
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE

Remarks— Analysed Parameter of above sample in within permissible limit

Memo No 125/07 / Chapra, Dated 12.08.2025

Copy forwarded to Executive Engineer, P.H division, Chapra/AE

P.H sub division, Chapra/Mashrak/Sonepur/J.E.P.H section.....

*BDL-Below detection limit.

Sachin Kumar Singh.
Manager
 Edutech Model School
 Revelganj, Saran (Bihar)

Principal
 Edutech Model School.
 Revelganj, Saran

Chemist
 Signature of the Chemist
 P.H. Division, Chapra